

2nd Floor

| MTL # | MATERIAL DESCRIPTION | LOCATION | F/NF ¹ | COND. ² | % ACM | # SAMP. | QUANTITY |
|-------|---------------------------------|--|-------------------|--------------------|-------------------------------|---------|-----------|
| 25 | White spray-on ceiling material | 2078, 2064, 2032, 2002 | F | Good | 4% | 9 | 11,400 SF |
| 26 | Blue carpet mastic | 2078 | NF | Good | ND | 3 | N/A |
| 27 | Black cove base/mastic | All rooms except 2106, 2070, 2042a, 2036, 2014, 2108 | NF | Good | Cove base = ND Mastic = ND | 3 | N/A |

