

SECTION 1
1.2 Results Summary
Student Health Center

ACM SURVEY RESULTS

The following homogeneous building material types were sampled as part of this survey conducted May 29, 2003. Results are summarized in the table below:

MTL #	MATERIAL DESCRIPTION	LOCATION	F/NF ¹	COND. ²	% ACM	# SAMP.	QUANTITY
01	1' x 1' White fissured ceiling tile	Main entry (1000), 1204, 1223, 1225, stairway, hallway next to room 0105	F	Good	ND	3	N/A
02	12" x 12" Tan floor tile/mastic	Throughout except main entry, men's restroom 1, women's restroom 1, 1145, 1143, 1141, 1139, 1137, 1135, 1133, 1129, 1131, 1125, 1119, 1108, 1108a, 1108b, 1108c, 1108d, 1104, 1190a, 1201, 1203, 1205, 1204, 1207, 1209, 1211, 1225, 0109, 0115, 0101, 0105a	NF	Good	Floor tile = 4% Mastic = 5%	3	17,000 SF
03	6" Brown cove base/mastic	Throughout except main entry (1000), men's restroom, women's restroom, 1145, 1143, 1139, 1141, 1137, 1135, 1133, 1129, 1131, 1119, 1108, 1108a, 1108b, 1108c, 1108d, 1104, 1190a, 1201, 1203, 1205, 1204, 1207, 1209, 1211.	NF	Good	Cove base = ND Mastic = 4%	3	3,000 SF
04	6" Black cove base/mastic	Main entry (1000) 1145, 1143, 1141, 1139, 1137, 1135, 1133, 1129, 1131, 1201, 1203, 1205, 1204, 1207, 1209, 1211, 1225 **Removed in 2009 – Main Entry men's and women's room.	NF	Good	Cove base = ND Mastic = ND	3	N/A
05	4" Brown cove base/mastic	1114a, 1111, 1160, 1190e, 1166, 1223	NF	Good	Cove base = ND Mastic = 4%	3	130 SF
06	Drywall (white) Joint compound*	Throughout except 1108, 1108a, 1108b, 1108c, 1108d, 1104, 1190a. **Removed in 2009 – Main Entry men's and women's room.	F	Good	Drywall = ND JC = <1%	3	60,000 SF
07	Blue carpet mastic	Main entry (1000), 1145, 1143, 1141, 1139, 1137, 1135, 1133, 1129, 1131, 1201, 1203, 1205, 1204, 1207, 1209, 1211, 1225	NF	Good	ND	3	N/A
08	Drywall (blue) Joint compound*	1102, 1156, 1143, 1141, 1139, 1137, 1135, 1133, 1129, 1166, 1218, 1221	F	Good	Drywall = ND JC = <1%	3	6,500 SF
09	1' x 1' White pinhole ceiling tile	1118, 1118a, 1114, 1114a, 1108	F	Good	ND	3	N/A
10	Drywall (pink) Joint compou						

